





- NOTES
1. THE LV ASSEMBLY IS DEAD FRONT WITH FLEXIBLE INSULATING BOOTS FITTED TO DISTRIBUTOR TERMINALS. ASSEMBLY IS IP21 FROM THE TOP ONLY. THE COVERS DO NOT PROTECT PURPOSEFUL TOUCH FROM UNDERNEATH.
 2. PHASE IDENTIFICATION
 - 2.1. T (Top) - L1 - RED
 - 2.2. M (Middle) - L2 - WHITE
 - 2.3. B (Bottom) - L3 - BLUE
 3. WIRE COLOURS -
RD - RED
BL - BLUE
WH - WHITE
BK - BLACK
OR - ORANGE
GY - GREY
GN/YE - GREEN/YELLOW
 4. FUSE LINKS ARE NOT PROVIDED.
 5. SWITCH UP FOR CONNECTING METER IN SERIES WITH MDI.

AUSGRID : 265242-3

REV	DATE	DESCRIPTION	DWN	APP
B	03/07/2023	ADDED GPO	P.W	J.J
A	09/03/2023	INITIAL SCHEMATIC	P.W	J.J

PROJECT: AUSGRID CHAMBER - STOCKCODE: 181790
ASSEMBLY ID: VF224209-AUS04
DESCRIPTION: 2500A TXF DISCONNECTOR + 800A S/F + 3X400A F/S
RATINGS: 2000A, 415V, 30kA 3s, FORM 1, IP (NOTE 1)
INSTALLATION TYPE: LV CHAMBER SUBSTATION



WEBER SOUTH PACIFIC PTY LTD
PO BOX 4264 Eight Mile Plains
Queensland Australia
TEL. (07) 3841 6899
FAX. (07) 3841 6877
EMAIL:- sales@webersouthpacific.com.au
THIS DRAWING AND SPECIFICATIONS HEREIN MUST NOT BE REPRODUCED OR COPIED IN PART OF WHOLE WITHOUT THE PRIOR PERMISSION OF WEBER SOUTH PACIFIC.

Scale: NTS
DO NOT SCALE
Tolerance: N/A
ALL DIMENSIONS IN MM UNLESS NOTED OTHERWISE

Standard: AS/NZS 61439.2
Drawing: SCHEMATIC
SHEET 1 OF 1

Client: AUSGRID
Part Number: VF224209-AUS04
Drawing Number: 00015-SC20
Size: A3
Type: 2D
Revision: B

NOT FOR CONSTRUCTION