


NOTES :

1. THE FOLLOWING INFORMATION IS OBTAINED FROM THE PROJECT DESIGN DRAWINGS :
 - a. POLE LENGTH AND STRENGTH.
 - b. SPECIAL FOUNDATION REQUIREMENTS.
 - c. POLE EMBEDMENT DEPTH.
 - d. CONDUCTOR SIZE.
 - e. STAY REQUIREMENTS.
 - f. DEVIATION ANGLE.
2. THE LOAD AND DEVIATION ALLOWABLE ON THE EYEBOLT IS TO BE DETERMINED FROM DRG : 520324.
3. POLES SHALL BE DRILLED, SCARFED AND DRESSED ON SITE. DRILLING AND SCARFING TO BE TREATED WITH APPROVED PRESERVATIVES.
4. EYEBOLTS ARE TO BE INSTALLED IN THE DIRECTION OF THE OVERHEAD CONDUCTORS.
5. ALL BOLTS PASSING THROUGH TIMBER ARE TO BE COATED WITH GRAPHITE GREASE.
6. POLE STEPS ARE TO BE INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF NS125.
7. WHEN INSTALLING A SINGLE CABLE, LEAVE A CABLE TAIL OF APPROXIMATELY 1m FOR A POSSIBLE FUTURE EXTENSION.
8. PRE-INSULATED ALUMINIUM COMPRESSION SLEEVES TO BE USED WHEN REQUIRED TO JOIN CONDUCTORS.

10	STEP - POLE, SCREW-IN (SEE NOTE 6)	250144	185198	A/R	A/R
9	SLEEVE - COMPRESSION, NON TENSION, PRE-INSULATED (TO SUIT 95mm ² LV ABC)		H19073		
	SLEEVE - COMPRESSION, PRE-INSULATED (TO SUIT 150mm ² LV ABC)	514053	150987	-	4
	SLEEVE - COMPRESSION, NON TENSION, PRE-INSULATED (TO SUIT 25mm ² LV ABC)	514053	176654		
8	CLAMP - WALL FACE		H19219	2	-
7	CAP - END PUSH ON (TO SUIT 25mm ² LV ABC)		H109447		
	CAP - END, PUSH ON (TO SUIT 95mm ² & 150mm ² LV ABC)		H77222	4	-
6	CLAMP - TERMINATION (TO SUIT 2x25mm ² OR 4x25mm ² LV ABC)		H113464		
	CLAMP - TERMINATION (TO SUIT 2x95mm ² OR 4x95mm ² LV ABC)		176651	1	2
	CLAMP - TERMINATION (TO SUIT 4x150mm ² LV ABC)		176652		
5	WASHER - FLAT, M20, GALVANISED	518081	177986	1	2
4	WASHER - CONICAL, M20, GALVANISED	518082	H39655	1	2
3	WASHER - SQUARE, 75x75x6mm, GALVANISED (Ø22mm HOLE)	518081	H39231	2	4
2	EYEBOLT - M20, GALVANISED (LENGTH TO SUIT POLE)(SEE NOTES 2 & 4)	513653		1	2
1	POLE - TIMBER (AS REQUIRED)	513988		1	1
ITEM	DESCRIPTION	DRG.NO	STOCK CODE	QTY	
				SINGLE CABLE	PARALLEL CABLE



ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE.

DO NOT SCALE.

CAD DRAWING
DO NOT MANUALLY AMEND
A M E N D M E N T S
DWN: PATRICIA RIOS
CHKD: PHILLIP JONES
DATE: 02/01/2020
POLE STEPS ADDED,
ARRANGEMENT REVERTED
TO PREVIOUS DESIGN.
NOTES & MATERIAL LIST
AMENDED.

APP'D by: GLENN FORD



145 NEWCASTLE RD WALLSEND,
NSW 2287

SCALE	1:10
DESIGNED	-
DRAWN	P.K
CHECKED	D.R.G
APPROVED	I NICOLS
DATE	24/02/94
PROJECT NUMBER	NET-STD
PROJTRAK NUMBER	STD

STANDARD CONSTRUCTION
LV ABC TERMINATION
CONSTRUCTION
1-71

SIZE	DRAWING No	SHEET	AMD
A3	513982	01	12