



**NOTES :**

1. THE FOLLOWING INFORMATION IS OBTAINED FROM THE PROJECT DESIGN DRAWINGS :
  - a. POLE LENGTH AND STRENGTH.
  - b. SPECIAL FOUNDATION REQUIREMENTS.
  - c. POLE EMBEDMENT DEPTH.
  - d. CONDUCTOR SIZE.
  - e. VARIATIONS TO STANDARD CROSSARM REQUIREMENTS.
  - f. STAY REQUIREMENTS.
  - g. DEVIATION ANGLE.
  - h. ASSESSED EARTHING REQUIREMENTS.
2. THE MAXIMUM LINE DEVIATION ANGLE TO BE CONSTRUCTED ON THIS ARRANGEMENT IS TO BE DETERMINED BY THE LINE DESIGNER.
3. POLE STEPS ARE TO BE INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF NS126.
4. IN AREAS WHERE THE 11KV NETWORK CANNOT BE WORKED ON USING LIVE LINE TECHNIQUES, UNDERBUILT CIRCUITS SHALL BE INSTALLED WITH A MINIMUM CLEARANCE OF 1200mm. IN AREAS WHERE THE 11KV NETWORK CAN BE WORKED ON USING LIVE LINE TECHNIQUES, UNDERBUILT CIRCUITS SHALL BE INSTALLED WITH A MINIMUM CLEARANCE OF 2500mm.
5. ALL BOLTS AND INSULATOR PINS PASSING THROUGH TIMBER ARE TO BE COATED WITH GRAPHITE GREASE.
6. POLES SHALL BE DRILLED, SCARFED AND DRESSED ON SITE. DRILLING AND SCARFING TO BE TREATED WITH APPROVED PRESERVATIVES.
7. IF THE CONDUCTOR DEVIATES AT THE INSULATOR, USE THE ANGLE TYPE CONDUCTOR TIE ARRANGEMENT, OTHERWISE USE THE INTERMEDIATE TYPE CONDUCTOR TIE ARRANGEMENT AS SHOWN ON DRG : 514038.

15	STEP - POLE, SCREW-IN (SEE NOTE 3)	250144	185198	A/R
14	TIE - CONDUCTOR, HIGH VOLTAGE, SUPPORT ARRANGEMENT	514038		4m
13	INSULATOR - 11/22KV AERODYNAMIC, (22/450) & PIN ARRANGEMENT	513997		3
12	BLOCK - GAIN, ALUMINIUM, 100mm		146274	1
11	WASHER - FLAT, M20, GALVANISED	518081	177986	1
10	WASHER - CONICAL, M20, GALVANISED	518082	H39655	1
9	WASHER - SQUARE, 75x75x6mm, GALVANISED (Ø22mm HOLE)	518081	H39231	2
8	BOLT & NUT - M20, HEX., GALVANISED (LENGTH TO SUIT POLE)	515466		1
7	WASHER - CONICAL, M12, GALVANISED	518082	H39639	1
6	WASHER - FLAT, M12, GALVANISED	518081	177982	2
5	BOLT & NUT - M12x130mm, HEX., GALVANISED	515466	46805	1
4	CROSSARM - 2700x100x100mm, TYPE T, HARDWOOD	514375	H23656	1
3	SCREW - COACH, M12x100mm, GALVANISED		H40484	1
2	BRACE - CROSSARM, ANGLE, 1524x50x50x6mm, GALVANISED	514382	H17291	1
1	POLE - TIMBER (AS REQUIRED)	513988		1

ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE. DO NOT SCALE.

CAD DRAWING DO NOT MANUALLY AMEND	
<b>A M E N D M E N T S</b>	
DWN: PATRICIA RIOS	CHKD: PHIL JONES
DATE: 03/09/2007	NOTE 4 AMENDED.
APP'D by: STEPHEN CONNOR	
DWN: PATRICIA RIOS	CHKD: PHILLIP JONES
DATE: 16/08/2019	M20 WASHER ADDED. NOTES & MATERIAL LIST AMENDED.
APP'D by: GLENN FORD	

NETWORK STANDARD

145 NEWCASTLE RD WALLSEND, NSW 2287

ITEM	DESCRIPTION	DRG. No	STOCK CODE	QTY
SCALE	1:25	STANDARD CONSTRUCTION		
DESIGNED	PHIL JONES	11kV 3/4 OFFSET ARM		
DRAWN	PATRICIA RIOS	CONSTRUCTION		
CHECKED	PHIL JONES	2-4		
APPROVED	STEPHEN CONNOR			
DATE	05/12/06			
PROJECT NUMBER	STD			
PROJTRAK NUMBER	-	SIZE	DRAWING No	SHEET
		A3	175879	01
				AMD
				2