



- NOTES :**
- THE FOLLOWING INFORMATION IS OBTAINED FROM THE PROJECT DESIGN DRAWINGS:
 - POLE LENGTH AND STRENGTH.
 - SPECIAL FOUNDATION REQUIREMENTS.
 - POLE EMBEDMENT DEPTH.
 - CONDUCTOR SIZE.
 - STAY REQUIREMENTS.
 - DEVIATION ANGLE.
 - THE MAXIMUM LINE DEVIATION ANGLE TO BE CONSTRUCTED ON THIS ARRANGEMENT IS TO BE DETERMINED BY THE LINE DESIGNER.
 - POLE STEPS ARE TO BE INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF NS128.
 - IN AREAS WHERE THE 11kV NETWORK CANNOT BE WORKED ON USING LIVE LINE TECHNIQUES, UNDERBUILT CIRCUITS SHALL BE INSTALLED WITH A MINIMUM CLEARANCE OF 1200mm. IN AREAS WHERE THE 11kV NETWORK CAN BE WORKED ON USING LIVE LINE TECHNIQUES, UNDERBUILT CIRCUITS SHALL BE INSTALLED WITH A MINIMUM CLEARANCE OF 2500mm.
 - POLES SHALL BE DRILLED, SCARFED AND DRESSED ON SITE. DRILLING AND SCARFING TO BE TREATED WITH APPROVED PRESERVATIVES.
 - ALL BOLTS PASSING THROUGH TIMBER ARE TO BE COATED WITH GRAPHITE GREASE.
 - REFER TO DESIGNER SAFETY REPORT D26/3377 FOR ATYPICAL HAZARDS ASSOCIATED WITH THIS STANDARD CONSTRUCTION.

8	STEP - POLE, SCREW-IN (SEE NOTE 3)	250144	185198	A/R
7	CLAMP - SUPPORT, ARMOUR GRIP (TO SUIT CONDUCTOR)	514132		3
6	INSULATOR - 22KV POST, CLAMP TOP, MOUNTED ON GAIN BASE BRACKET		178293	3
5	WASHER - FLAT, M20, GALVANISED	518081	177986	6
4	WASHER - CONICAL, M20, GALVANISED	518082	H39655	6
3	WASHER - SQUARE, 75x75x6mm, GALVANISED (Ø22mm HOLE)	518081	H39231	12
2	BOLT & NUT - M20, HEX., GALVANISED (LENGTH TO SUIT POLE)	515466		6
1	POLE - TIMBER (AS REQUIRED)	513988		1
ITEM	DESCRIPTION	DRG. No	STOCK CODE	QTY

NETWORK STANDARD

 **Ausgrid**

42 HONEYSUCKLE DRIVE,
NEWCASTLE WEST NSW 2300

SCALE	1:20	STANDARD CONSTRUCTION 11kV VERTICAL DELTA CONSTRUCTION 2-200			
DESIGNED	PHIL JONES				
DRAWN	PATRICIA RIOS				
CHECKED	PHIL JONES				
APPROVED	STEPHEN CONNOR				
DATE	03/09/2007				
PROJECT NUMBER	STD				
TRIM REF NUMBER	-	SIZE	DRAWING No	SHEET	REV
		A3	183908	1	3