



- NOTES :**
- THE FOLLOWING INFORMATION IS OBTAINED FROM THE PROJECT DESIGN DRAWINGS:
 - POLE LENGTH AND STRENGTH.
 - SPECIAL FOUNDATION REQUIREMENTS.
 - POLE EMBEDMENT DEPTH.
 - CONDUCTOR SIZE.
 - STAY REQUIREMENTS.
 - DEVIATION ANGLE.
 - THE MAXIMUM LINE DEVIATION ANGLE TO BE CONSTRUCTED ON THIS ARRANGEMENT IS TO BE DETERMINED BY THE LINE DESIGNER.
 - POLE STEPS ARE TO BE INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF NS128.
 - IN AREAS WHERE THE 11kV NETWORK CANNOT BE WORKED ON USING LIVE LINE TECHNIQUES, UNDERBUILT CIRCUITS SHALL BE INSTALLED WITH A MINIMUM CLEARANCE OF 1200mm. IN AREAS WHERE THE 11kV NETWORK CAN BE WORKED ON USING LIVE LINE TECHNIQUES, UNDERBUILT CIRCUITS SHALL BE INSTALLED WITH A MINIMUM CLEARANCE OF 2500mm.
 - ALL BOLTS PASSING THROUGH TIMBER ARE TO BE COATED WITH GRAPHITE GREASE.
 - POLES SHALL BE DRILLED, SCARFED AND DRESSED ON SITE. DRILLING AND SCARFING TO BE TREATED WITH APPROVED PRESERVATIVES.
 - ARRANGEMENT 1 OF THIS STRUCTURE IS DESIGNED FOR USE WHERE THE LINE DEVIATION ANGLE IS LESS THAN 10°. ARRANGEMENT 2 OF THIS STRUCTURE IS DESIGNED FOR USE WHERE THE LINE DEVIATION ANGLE IS BETWEEN 10° AND 30°.
 - TO MAINTAIN THE INTEGRITY OF A COVERED SYSTEM, IT IS ESSENTIAL THAT ALL STRIPPED AND PUNCTURED INSULATION IS CONTAINED WITHIN THE APPROPRIATE INSULATING COVER.
 - SURGE ARRESTERS ARE TO BE INSTALLED ON AN OVERHEAD CCSX CONDUCTOR SYSTEM IN ACCORDANCE WITH THE REQUIREMENTS OF NS126. IF A SURGE ARRESTER IS TO BE INSTALLED ON THIS CONSTRUCTION, IT IS TO BE INSTALLED AS PER THE RELEVANT COVERED CONDUCTOR ARRANGEMENT SPECIFIED IN DRG: 265905.
 - A CCSX EARTHING POINT IS TO BE INSTALLED WHERE REQUIRED FOR OPERATIONAL PURPOSES OR AT LOCATIONS SPECIFIED IN NS126. ONLY ONE SET OF EARTHING POINTS IS REQUIRED ON THIS CONSTRUCTION. THE EARTHING POINTS CAN BE INSTALLED AT EITHER OF THE ALTERNATE LOCATIONS INDICATED.
 - REFER TO DESIGNER SAFETY REPORT D24/83482 FOR ATYPICAL HAZARDS ASSOCIATED WITH THIS STANDARD CONSTRUCTION.

ITEM	DESCRIPTION	DRG. No	STOCK CODE	QTY
11	STEP - POLE, SCREW-IN (SEE NOTE 3)	250144	185198	A/R
10	EARTH - PARKING, DEVICE, IPC CC TO EPD (ENSTO REF. SLW26.A2) (SEE NOTE 10)		186865	3
9	WIRE - TIE, PREFORMED, INSULATED, FOR CCSX159 (SET OF 6) (ENSTO REF. SO216.157)		186874	1
	WIRE - TIE, PREFORMED, INSULATED, FOR CCSX62 (SET OF 6) (ENSTO REF. SO216.62)		186875	
	WIRE - TIE, PREFORMED, INSULATED, FOR CCSX25 (SET OF 6) (ENSTO REF. SO216.25)		186876	
8	INSULATOR - PIN POST, SHORT STUD		144584	3
7	BRACKET - INSULATOR, GALVANISED (FOR ARR-2) (SEE NOTE 7)		144634	3
	BRACKET - INSULATOR, GALVANISED (FOR ARR-1) (SEE NOTE 7)		144626	
6	SCREW - COACH, M16x130mm, GALVANISED		50401	3
5	WASHER - FLAT, M20, GALVANISED	518081	177986	3
4	WASHER - CONICAL, M20, GALVANISED	518082	H39655	3
3	WASHER - SQUARE, 75x75x6mm, GALVANISED (Ø22mm HOLE)	518081	H39231	3
2	BOLT & NUT - M20, HEX, GALVANISED (LENGTH TO SUIT POLE)	515466		3
1	POLE - TIMBER (AS REQUIRED)	513988		1

ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE. DO NOT SCALE.

CAD DRAWING
DO NOT MANUALLY AMEND
A M E N D M E N T S
DWN: P.R.
CHKD: P.J.
APPD: G.F.
DATE: 09/05/2024
ITEM 10 ADDED. MATERIAL LIST & NOTES AMENDED.

NETWORK STANDARD
Ausgrid
145 NEWCASTLE RD WALLSEND,
NSW 2287

SCALE	1:20	STANDARD CONSTRUCTION 11kV VERTICAL DELTA CONSTRUCTION 2-200CCSX			
DESIGNED	J.BROOKS				
DRAWN	P.RIOS				
CHECKED	P.JONES				
APPROVED	G.FORD				
DATE	28/03/2024				
PROJECT NUMBER	STD				
PROJTRAK NUMBER		SIZE	DRAWING No	SHEET	AMD
		A3	265895	1	1