

TOTAL LINE DEVIATION  
LESS THAN OR EQUAL TO 60°.


(SEE NOTES 1 & 2)

(SEE NOTE 4)

**NOTES :**

1. USE 150m MAXIMUM SPAN LENGTH ADSS CABLE WITH THIS CONSTRUCTION.
2. 72 OR 144 CORE STANDARD ADSS OPTICAL FIBRE CABLE IS TO BE USED UNDER NORMAL OPERATING CONDITIONS.  
72 OR 144 CORE ANTI-TRACKING ADSS OPTICAL FIBRE CABLE IS TO BE USED WITH SECONDARY SYSTEMS APPROVAL IN HIGH POLLUTION ENVIRONMENTS & IN LOCATIONS WHERE A HIGH ELECTRIC FIELD EXISTS.
3. THIS ARRANGEMENT IS FOR SUSPENSION CONSTRUCTIONS WITH A LINE DEVIATION ANGLE BETWEEN 30° AND 60°.
4. FIBERLIGN DIELECTRIC SUSPENSION CLAMP OFDSC-120125-3 IS TO BE USED ON THE 72 CORE STANDARD ADSS OPTICAL FIBRE 150m MAXIMUM SPAN LENGTH CABLE.  
FIBERLIGN DIELECTRIC SUSPENSION CLAMP OFDSC-130135-1 IS TO BE USED ON THE 72 CORE ANTI-TRACKING ADSS OPTICAL FIBRE 150m MAXIMUM SPAN LENGTH CABLE.  
FIBERLIGN DIELECTRIC SUSPENSION CLAMP OFDSC-190195 IS TO BE USED ON THE 144 CORE STANDARD ADSS OPTICAL FIBRE 150m MAXIMUM SPAN LENGTH CABLE.  
FIBERLIGN DIELECTRIC SUSPENSION CLAMP OFDSC-140145-3 IS TO BE USED ON THE 144 CORE ANTI-TRACKING ADSS OPTICAL FIBRE 150m MAXIMUM SPAN LENGTH CABLE.

6	CLAMP - SUSPENSION, FIBERLIGN DIELECTRIC (PLP PART No. OFDSC-140145-3) (SEE NOTE 4)	2	
	CLAMP - SUSPENSION, FIBERLIGN DIELECTRIC (PLP PART No. OFDSC-190195) (SEE NOTE 4)		
	CLAMP - SUSPENSION, FIBERLIGN DIELECTRIC (PLP PART No. OFDSC-130135-1) (SEE NOTE 4)		
	CLAMP - SUSPENSION, FIBERLIGN DIELECTRIC (PLP PART No. OFDSC-120125-3) (SEE NOTE 4)		
5	YOKE - DOUBLE SUSPENSION (PLP PART No. YABCOF-16-300)	1	
4	BUCKLE - STRAPPING SEAL, 12.7mm, STAINLESS STEEL	2	
3	STRAP - BANDIT, 12.7mm, STAINLESS STEEL (LENGTH TO SUIT POLE)	A/R	
2	HOOK - M16, SAFETY PLATE (PLP PART No. GSHP-16)	1	
1	CABLE - OPTICAL FIBRE, 144 CORE, ADSS, ANTI-TRACKING, 150m (SEE NOTES 1 & 2)	A/R	
	CABLE - OPTICAL FIBRE, 144 CORE, ADSS, STANDARD, 150m (SEE NOTES 1 & 2)		
	CABLE - OPTICAL FIBRE, 72 CORE, ADSS, ANTI-TRACKING, 150m (SEE NOTES 1 & 2)		
	CABLE - OPTICAL FIBRE, 72 CORE, ADSS, STANDARD, 150m (SEE NOTES 1 & 2)		
ITEM	DESCRIPTION	DRG. No.	QTY



CAD DRAWING DO NOT MANUALLY AMEND A M E N D M E N T S	DWN: PATRICIA RIOS CHKD: ALFRED FREESTONE	DATE: 02/04/2019 NOTES & MATERIAL LIST AMENDED.	APP'D by: GLENN FORD
1	1	2	3

NETWORK STANDARD

145 NEWCASTLE RD WALLSEND,  
NSW 2287

SCALE	1:7.5	STANDARD CONSTRUCTION			
DESIGNED	PHILLIP JONES	ADSS FIBRE OPTIC CABLE RETROFIT ON			
DRAWN	PATRICIA RIOS	CONCRETE POLE - ADSS SUSPENSION CONSTRUCTION			
CHECKED	ALFRED FREESTONE	30° TO 60° LINE DEVIATION ANGLE			
APPROVED	GLENN FORD	WITH SPAN LENGTHS UP TO 150m			
DATE	17/11/14	SIZE	DRAWING No	SHEET	AMD
PROJECT NUMBER	STD	A3	234582	01	1
PROJTRAK NUMBER	-				