



NOTES:

1. EARTH BAR SHALL BE WELDED TO LIGHTNING SPIRE PRIOR TO HOT DIP GALVANISING.
2. WHERE WELDING OR DRILLING IS CARRIED OUT ON SITE ALL WELDS TO BE CLEANED, WIRE BRUSHED, ALL DRILL HOLES CLEANED OF SWarf BEFORE PAINTING WITH COLD GALVANISING PAINT OR EQUIVALENT.

REFERENCE DRAWINGS

- FLOODLIGHTING/LIGHTNING SPIRE 2 LIGHT ASSEMBLY GA - 162013
- FLOODLIGHTING/LIGHTNING SPIRE 4 LIGHT ASSEMBLY GA - 169818
- LIGHTNING SPIRE EARTHING DETAILS - 162611

OBSOLETE

ITEM	DESCRIPTION	QTY.
1	FLAT - 50 x 5 x 340LG AS3679.1-300	1

CAD DRAWING DO NOT MANUALLY AMEND A M E N D M E N T S	
DWN: AARON BULBERT	CHKD: BEN STADDON
APP'D: MICHAEL GRIFFITHS	DATE: 08/02/2013
ADDED NOTES 1 & 2	
DWN: RAY DEAL	CHKD: THOMAS PHILLIPS
APP'D: THOMAS PHILLIPS	DATE: 04/04/2019
OBSOLETE	



145 NEWCASTLE RD WALLSEND,
NSW 2287

SCALE	1:10
DESIGNED	PETER STOREY
DRAWN	RAY DEAL
CHECKED	PETER STOREY
APPROVED	ROSS HUGHES
DATE	22/10/10
PROJECT NUMBER	STD
PROJTRAK NUMBER	

STANDARD CONSTRUCTION LIGHTNING SPIRE EARTH BAR DETAILS			
SIZE	DRAWING No	SHEET	AMD
A3	161887	01	2