



ALL EARTHING REQUIREMENTS MUST MEET NS116 "DESIGN STANDARDS FOR DISTRIBUTION EARTHING"

11kV NU-LEC TYPE N15
 RECLOSER - CONTROLLING POLE MOUNTED REGULATOR
 A1-185171
 SCALE 150

NOTE:
 THE LOCATION OF THE REGULATOR INSTALLATION AND POSITION OF THE CONTROLS (POLE OR GROUND MOUNTED) IS TO BE DETERMINED IN CONSULTATION WITH OPERATIONAL STAFF BEFORE EACH PROJECT DESIGN IS FINALISED REFER TO NEG VR-02 FOR FURTHER INFORMATION

11kV 100A & 200A TWO OR THREE UNIT POLE MOUNTED REGULATOR OPTIONS

- 2 UNIT REGULATOR WITH POLE MOUNTED CONTROL - A1-185172
- 3 UNIT REGULATOR WITH POLE MOUNTED CONTROL - A1-185173
- 2 UNIT REGULATOR WITH GROUND MOUNTED CONTROLLER - A1-185174
- 3 UNIT REGULATOR WITH GROUND MOUNTED CONTROLLER - A1-185175

SCALE 150

CAD DRAWING DO NOT MANUALLY AMEND	AMENDMENTS	0	INITIAL ISSUE
	DWN: NATALIE SINGLETON	1	REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS
	CHKD: PETER STOREY	2	REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS
APP'D By: ROSS HUGHES	3	REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	
DWN: NATALIE SINGLETON	4	REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	
CHKD: PETER STOREY	5	REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	
DATE: 11/04/2008	6	REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	
MINIMUM DISTANCE BETWEEN POLES ADDED	7	REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	
NOTES ADDED	8	REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	
RECLOSER REPOSITIONED	9	REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	
CONTROL BOXES UPDATED	10	REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	
APP'D By: ROSS HUGHES	11	REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	
DWN: NATALIE SINGLETON	12	REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	
CHKD: STEPHEN LILLISS		REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	
DATE: 12/09/2008		REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	
ARRESTOR & CROSSARM REMOVED FROM RECLOSER		REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	
APP'D By: PETER STOREY		REGULATOR UPDATED TO REFLECT CORRECT CONNECTIONS	

STANDARD CONSTRUCTION - 11kV NU-LEC CONTROLLING POLE MOUNTED REGULATORS	A1-185171
ASSOCIATED DRAWINGS	

DESIGN
 165 NEWCASTLE RD WALLSEND, NSW 2287
 TEL 4951 9388 FAX 4951 9389

EnergyAustralia

SCALE	AS SHOWN
DESIGNED	WILLIAM GRAHAM
DRAWN	NATALIE SINGLETON
CHECKED	WILLIAM GRAHAM
APPROVED	ROSS HUGHES
DATE	07/11/07
PRJ/TRK No.	
PROJECT NUMBER	STD

STANDARD DESIGN	DRAWING No	182685	SHEET	01	AMD	3	SIZE	A1
-----------------	------------	--------	-------	----	-----	---	------	----