



CONSTRUCTION

1-1
1-3
1-14
1-100
1-103
1Ø 11kV
DROPOUTS

2-5CCT
2-6CCT
2-7CCT
2-14CCT
2-38CCT
2-42CCT
2-61CCT
2-106CCT
2-107CCT

2-5
2-14
2-61
2-414

FOR 1Ø
AND 2Ø
RURAL
APPLICATIONS

CAD DRAWING
DO NOT MANUALLY AMEND
A M E N D M E N T S
DWN: GARRY CRAIG
CHKD: GARRY CRAIG
APP'D: GLENN FORD
DATE: 02/05/2014
AUSGRID BORDER
APPLIED.
10

NETWORK STANDARD

Ausgrid

DESIGN & ENGINEERING BRANCH
145 NEWCASTLE RD WALLSEND, NSW 2287
Ph 02 4951 9388
Fax 02 4951 9389

SCALE	1:20
DESIGNED	-
DRAWN	P.S
CHECKED	-
APPROVED	G SKINNER
DATE	13/11/96
PROJECT NUMBER	STD
PROJTRAK NUMBER	

STANDARD CONSTRUCTION			
2100mm CROSSARMS FOR			
LV 11kV AND 33kV			
CONSTRUCTION DETAILS			
SIZE	DRAWING No	SHEET	AMD
A3	514374	01	10